

ABSOLUTE PRESSURE TRANSMITTER

DATA SHEET

FKA, FDA--5

The FCX -AII absolute pressure transmitter accurately measures absolute pressure and transmits a proportional 4 to 20mA signal.

The transmitter utilizes a unique micromachined capacitance silicon sensor with state-of-the-art micro-processor technology to provide exceptional performance and functionality.

FEATURES

1. High accuracy

0.2% accuracy for all calibrated spans is a standard feature for all AP models covering 1.6kPa {0.016bar} range to 3000kPa {30bar} high pressure range. 0.1% accuracy is available as option. Fuji's micro-capacitance silicon sensor assures this accuracy for all suppressed calibration ranges without additional adjustment.

2. Minimum environmental influence

The "Advanced Floating Cell" design which protects the pressure sensor against changes in temperature, and over-pressure substantially reduces total measurement error in actual field applications.

3. Fuji/HART® bilingual communications protocol and FOUNDATION™ fieldbus and Profibus™ compatibility

FCX -AII series transmitter offers bilingual communications to speak both Fuji proprietary protocol and HART®. Any HART® compatible devices can communicate with FCX -AII. Further, by upgrading electronics FOUNDATION™ fieldbus and Profibus™ are also available.

4. Application flexibility

Various options that render the FCX -AII suitable for almost any process applications include:

- Full range of hazardous area approvals
- Built-in RFI filter and lightning arrester
- 5-digit LCD meter with engineering unit
- Stainless steel electronics housing
- Wide selection of materials

5. Burnout current flexibility (Under Scale: 3.2 to 4.0mA, Over Scale: 20.0 to 22.5mA)

Burnout signal level is adjustable using Model FXW Hand Held Communicator (HHC) to comply with NAMUR NE43.

6. Dry calibration without reference pressure

Thanks to the best combination of unique construction of mechanical parts (Sensor unit) and high performance electronics circuit (Electronics unit), reliability of dry calibration without reference pressure is at equal level as wet calibration.



SPECIFICATIONS

Functional specifications

Type:

FKA: Smart, 4 to 20mA DC + Fuji/Hart™ digital signal

FDA: FOUNDATION™ Fieldbus and Profibus™

Service:

Liquid, gas, or vapour

Span, range, and overrange limit:

Type	Span limit [kPa abs] {bar abs}		Range limit [kPa abs] {bar abs}	Overrange limit [MPa] {bar}
	Min.	Max.		
FKA□01	1.6 {0.016}	16 {0.16}	0 to +16 {0 to +0.16}	0.5 {5}
FKA□02	1.6 {0.016}	130 {1.3}	0 to +130 {0 to +1.3}	0.5 {5}
FKA□03	5 {0.05}	500 {5}	0 to +500 {0 to +5}	1.5 {15}
FKA□04	30 {0.3}	3000 {30}	0 to +3000 {0 to +30}	9 {90}

Remark: To minimize environmental influence, span should be greater than 1/40 of the max. span in most applications.

- The maximum span of each sensor can be converted to different units using factors as below.

1MPa abs=10³kPa abs=10bar abs=10.19716kgf/cm² abs
=145.0377psi abs

1kPa abs=10mbar abs=101.9716mmH₂O abs
=4.01463inH₂O abs=7.50062mmHg abs

Output signal:

4 to 20mA DC with digital signal superimposed on the 4 to 20mA signal.


Digital signal based on FOUNDATION™ fieldbus and Profibus™

Power supply:

Transmitter operates on 10.5V to 45V DC at transmitter terminals.

10.5V to 32V DC for the units with optional arrester.

Load limitations: see figure below



Note: For communication with HHC⁽¹⁾ (Model: FXW), min. of 250Ω is required.

Hazardous locations:

Authorities	Intrinsic safety																					
ATEX (pending)	Ex II 1 GD Ex ia IIC T5 Tamb = -40°C to +50°C Ex ia IIC T4 Tamb = -40°C to +70°C Entity Parameters: Ui=28V, li=93.3mA, Pi=0.66W, Ci=25.18nF (Without Arrester), Ci=35.98nF (With Arrester), Li=0.694mH																					
Factory Mutual (pending)	Class I II III Div.1 Groups A, B, C, D, E, F, G T4 Entity Type 4X <table border="1"> <thead> <tr> <th colspan="2">Model code</th> <th>Tamb</th> </tr> <tr> <th>9th digit</th> <th>13th digit</th> <th></th> </tr> </thead> <tbody> <tr> <td>A,B,C,D,J</td> <td>Y,G,N</td> <td>-40°C to +85°C</td> </tr> <tr> <td>L,P,M,1,2,3</td> <td>Y,G,N</td> <td>-20°C to +80°C</td> </tr> <tr> <td>Q,S,N,4,5,6</td> <td>Y,G,N</td> <td>-20°C to +60°C</td> </tr> <tr> <td>E,F,G,H,K</td> <td>Y,G,N</td> <td>-40°C to +60°C</td> </tr> <tr> <td>-</td> <td>W,A,D</td> <td>-10°C to +60°C</td> </tr> </tbody> </table> Entity Parameters: Vmax=42.4V, Imax=113mA, Pi=1W, Ci=35.98nF, Li=0.694mH	Model code		Tamb	9th digit	13th digit		A,B,C,D,J	Y,G,N	-40°C to +85°C	L,P,M,1,2,3	Y,G,N	-20°C to +80°C	Q,S,N,4,5,6	Y,G,N	-20°C to +60°C	E,F,G,H,K	Y,G,N	-40°C to +60°C	-	W,A,D	-10°C to +60°C
Model code		Tamb																				
9th digit	13th digit																					
A,B,C,D,J	Y,G,N	-40°C to +85°C																				
L,P,M,1,2,3	Y,G,N	-20°C to +80°C																				
Q,S,N,4,5,6	Y,G,N	-20°C to +60°C																				
E,F,G,H,K	Y,G,N	-40°C to +60°C																				
-	W,A,D	-10°C to +60°C																				
CSA (pending)	Class I Div.1 Groups A, B, C, D Class II Div.1 Groups E, F, G Class III Div.1 Temp Code T5 Tamb max = +50°C Temp Code T4 Tamb max = +70°C Entity Parameters: Vmax=28V, Imax=93mA, Ci=25.18nF (Without Arrester), Ci=35.98nF (With Arrester), Li=0.694mH																					
TIIS (pending)	Ex ia IIC T4 Tamb max = +60°C Entity Parameters: Ui=28V, li=94.3mA, Pi=0.66W, Ci=38.4nF, Li=0.694mH																					
IECEX Scheme (pending)	Ex ia IIC T4 IP66/67 Tamb = -40°C to +70°C Ex ia IIC T5 IP66/67 Tamb = -40°C to +50°C Entity Parameters: Ui=28V, li=93.3mA, Pi=0.66W, Ci=35.98nF, Li=0.694mH																					
NEPSI (pending)	Ex ia IIC T4 Ex d IIB+H ₂ T6 / Ex ia IIC T4 <table border="1"> <thead> <tr> <th colspan="2">Model code</th> <th>Tamb</th> </tr> <tr> <th>9th digit</th> <th>13th digit</th> <th></th> </tr> </thead> <tbody> <tr> <td>A,B,D,J</td> <td>Y,G,H,J,S,T,K</td> <td>-40°C to +85°C</td> </tr> <tr> <td>L,P,1,2</td> <td>Y,G,H,J,S,T,K</td> <td>-20°C to +80°C</td> </tr> <tr> <td>Q,S,4,5</td> <td>Y,G,H,J,S,T,K</td> <td>-20°C to +60°C</td> </tr> <tr> <td>E,F,H,K</td> <td>Y,G,H,J,S,T,K</td> <td>-40°C to +60°C</td> </tr> <tr> <td>-</td> <td>W,A,D</td> <td>-10°C to +60°C</td> </tr> </tbody> </table> Entity Parameters: Ui=42.4V, li=113mA, Pi=1W, Ci=35.98nF, Li=0.694mH	Model code		Tamb	9th digit	13th digit		A,B,D,J	Y,G,H,J,S,T,K	-40°C to +85°C	L,P,1,2	Y,G,H,J,S,T,K	-20°C to +80°C	Q,S,4,5	Y,G,H,J,S,T,K	-20°C to +60°C	E,F,H,K	Y,G,H,J,S,T,K	-40°C to +60°C	-	W,A,D	-10°C to +60°C
Model code		Tamb																				
9th digit	13th digit																					
A,B,D,J	Y,G,H,J,S,T,K	-40°C to +85°C																				
L,P,1,2	Y,G,H,J,S,T,K	-20°C to +80°C																				
Q,S,4,5	Y,G,H,J,S,T,K	-20°C to +60°C																				
E,F,H,K	Y,G,H,J,S,T,K	-40°C to +60°C																				
-	W,A,D	-10°C to +60°C																				

Authorities	Flameproof
ATEX (pending)	Ex II 2 GD Ex d IIC T6 IP66/67 T85°C Tamb = -40°C to +65°C Ex d IIC T5 IP66/67 T100°C Tamb = -40°C to +85°C
Factory Mutual (pending)	Class I Div.1 Groups B, C, D T6 Type 4X Class II III Div.1 Groups E, F, G T6 Type 4X Tamb max = +60°C
CSA	Class I Div.1 Groups C, D Class II Div.1 Groups E, F, G Class III Div.1 Note) "Seal Not Required" enclosure is allowed.
TIIS	Ex do IIB+H ₂ T4 Tamb max = +60°C Maximum process temp. = +120°C
IECEX Scheme (pending)	Ex d IIC T5 IP66/67 Tamb = -40°C to +85°C Ex d IIC T6 IP66/67 Tamb = -40°C to +65°C
NEPSI	Ex d IIB+H ₂ T6 Tamb = -40°C to +60°C

Authorities	Type n Nonincendive																					
ATEX (pending)	Ex II 3 GD Ex nL IIC T5 Tamb = -40°C to +50°C Ex nL IIC T4 Tamb = -40°C to +70°C Specific Parameters: Model without arrester: Ui=42.4V, li=113mA, Pi=1W, Ci=25.18nF, Li=0.694mH Model with arrester: Ui=32V, li=113mA, Pi=1W, Ci=35.98nF, Li=0.694mH Ex nA IIC T5 Tamb = -40°C to +50°C Ex nA IIC T4 Tamb = -40°C to +70°C Specific Parameters: Model without arrester: Umax=42.4V, Imax=113mA, Pmax=1W Model with arrester: Umax=32V, Imax=113mA, Pmax=1W																					
Factory Mutual (pending)	Class I II III Div.2 Groups A, B, C, D, F, G T4 Entity Type 4X <table border="1"> <thead> <tr> <th colspan="2">Model code</th> <th>Tamb</th> </tr> <tr> <th>9th digit</th> <th>13th digit</th> <th></th> </tr> </thead> <tbody> <tr> <td>A,B,C,D,J</td> <td>Y,G,N</td> <td>-40°C to +85°C</td> </tr> <tr> <td>L,P,M,1,2,3</td> <td>Y,G,N</td> <td>-20°C to +80°C</td> </tr> <tr> <td>Q,S,N,4,5,6</td> <td>Y,G,N</td> <td>-20°C to +60°C</td> </tr> <tr> <td>E,F,G,H,K</td> <td>Y,G,N</td> <td>-40°C to +60°C</td> </tr> <tr> <td>-</td> <td>W,A,D</td> <td>-10°C to +60°C</td> </tr> </tbody> </table>	Model code		Tamb	9th digit	13th digit		A,B,C,D,J	Y,G,N	-40°C to +85°C	L,P,M,1,2,3	Y,G,N	-20°C to +80°C	Q,S,N,4,5,6	Y,G,N	-20°C to +60°C	E,F,G,H,K	Y,G,N	-40°C to +60°C	-	W,A,D	-10°C to +60°C
Model code		Tamb																				
9th digit	13th digit																					
A,B,C,D,J	Y,G,N	-40°C to +85°C																				
L,P,M,1,2,3	Y,G,N	-20°C to +80°C																				
Q,S,N,4,5,6	Y,G,N	-20°C to +60°C																				
E,F,G,H,K	Y,G,N	-40°C to +60°C																				
-	W,A,D	-10°C to +60°C																				
CSA (pending)	Class I Div.2 Groups A, B, C, D Class II Div.2 Groups E, F, G Class III Div.2 Temp Code T5 Tamb max = +50°C Temp Code T4 Tamb max = +70°C Entity Parameters: Vmax=28V, Ci=25.18nF (Without Arrester), Ci=35.98nF (With Arrester), Li=0.694mH																					

Zero/span adjustment:

Zero and span are adjustable from the HHC⁽¹⁾. Zero and span are also adjustable externally from the adjustment screw (span adjustment is not available with 9th digit code "L, P, Q, S").

Damping:

Adjustable from HHC or local adjustment unit with LCD display. The time constant is adjustable between 0 to 32 seconds.

Zero elevation/suppression:

Zero can be elevated within the specified range limit of each sensor model.

Normal/reverse action:

Selectable from HHC⁽¹⁾.

Indication:

Analog indicator or 5-digit LCD meter, as specified.

Burnout direction: Selectable from HHC⁽¹⁾

If self-diagnostic detect transmitter failure, the analog signal will be driven to either "Output Hold", "Output Overscale" or "Output Underscale" modes.

"Output Hold":


Output signal is hold as the value just before failure happens.

"Output Overscale":

Adjustable within the range 20.0mA to 22.5mA from HHC⁽¹⁾

"Output Underscale":

Adjustable within the range 3.2mA to 4.0mA from HHC⁽¹⁾



Output Limits conforming the NAMUR NE43 by order.

Loop-check output:

Transmitter can be configured to provide constant signal 3.2mA through 21.6mA by HHC⁽¹⁾.

Temperature limit:

- Ambient: - 40 to +85°C
- (- 20 to +80°C for LCD indicator)
- (- 40 to +60°C for arrester option)

For explosionproof units (flameproof or intrinsic safety), ambient temperature must be within the limits specified by each standard.

- Process: - 40 to +85°C for silicone fill sensor
- Storage: - 40 to +90°C

Humidity limit: 0 to 100% RH

Communication:

With HHC⁽¹⁾ (Model FXW, consult Data Sheet No. EDS8-47), following items can be remotely displayed or configured.

Note: HHC's version must be higher than 6.0 (or FXW □□□□1-□3), for FCX-AII.

For supporting "Saturate current", "Write protect", and "History", HHC's version 6.3 or higher is necessary.

Items	Fuji Protocol with FXW		Hart Protocol	
	Display	Set	Display	Set
Tag No.	✓	✓	✓	✓
Model No.	✓	✓	—	—
Serial No. & Software Version	✓	—	✓	—
Engineering unit	✓	✓	✓	✓
Range limit	✓	—	✓	—
Measuring range	✓	✓	✓	✓
Damping	✓	✓	✓	✓
Output mode	✓	—	✓	—
Burnout direction	✓	✓	✓	✓
Calibration	✓	✓	✓	✓
Output adjust	—	✓	—	✓
Data	✓	—	✓	—
Self diagnoses	✓	—	✓	—
Printer (In case of FXW with printer option)	✓	—	—	—
External switch lock	✓	✓	✓	✓
Transmitter display	✓	✓	✓	✓
*Linearize	✓	✓	—	—

(Note) (1) HHC: Hand Held Communicator

Rerange	✓	✓	✓	✓
Saturate current	✓	✓	✓	✓
Write protect	✓	✓	✓	✓
History				
- Calibration history	✓	✓	✓	✓
- Ambient temperature history	✓	—	✓	—

***Local configurator with LCD display (option):**

Local configurator with 3 push button and LCD display can support all items (Fuji Protocol list) except "Linearize" function.

Programmable output linearization function:

Output signal can be characterized with "14 points linear approximation function" from HHC⁽¹⁾.

Fieldbus units:

- Digital signal
- Transmission technique: according to IEC61158-2
- Power supply: 9VDC...32VDC
- Base current: 16±2mA
- Transmission rate: 31,25 kbits/sec
- Profibus-PA: DPV1 version 3.0
- Fieldbus Foundation: FF-890/891

Performance specifications

Reference conditions, silicone oil fill, 316SS isolating diaphragms, 4 to 20mA analog output in linear mode.

Accuracy rating:

(including linearity, hysteresis, and repeatability).

(Standard)

For spans greater than 1/10 of URL: ±0.2% of span

For spans below 1/10 of URL:

$$\pm \left(0.1 + 0.1 \frac{0.1 \times \text{URL}}{\text{Span}} \right) \% \text{ of span}$$

(Option) (code: 21th digit H)

(Not available for Max span 16kPa abs, 130kPa abs)

For spans greater than 1/10 of URL: ±0.1% of span

For spans below 1/10 of URL:

$$\pm \left(0.05 + 0.05 \frac{0.1 \times \text{URL}}{\text{Span}} \right) \% \text{ of span}$$

Stability:

±0.2% of upper range limit (URL) for 10 years.

Temperature effect:

Effect per 28°C change between the limits of -40°C and +85°C

$$\text{Zero shift: } \pm \left(0.125 + 0.1 \frac{\text{URL}}{\text{Span}} \right) \%$$

$$\text{Total effect: } \pm \left(0.15 + 0.1 \frac{\text{URL}}{\text{Span}} \right) \%$$

Overrange effect:

Zero shift; ±0.2% of URL for any overrange to maximum limit

Supply voltage effect:

Less than 0.005% of calibrated span per 1V

Update rate:

60 msec

Step response:

Time constant: 0.08 s (at 23°C)

Dead time: 0.12 s (without electrical damping)

Mounting position effect:

Zero shift, less than 0.1kPa{1mbar} for a 10° tilt in any plane.

No effect on span. This error can be corrected by adjusting zero.

Dielectric strength:

500V AC, 50/60Hz 1 min., between circuit and earth.

Insulation resistance:

More than 100MΩ at 500V DC.

Internal resistance for external field indicator:

12Ω max (connected to test terminal CK+ and CK-)

Physical specifications

Electrical connections:

1/2-14NPT, Pg13.5, or M20 x 1.5

Process connections:

1/4-18 NPT on 54mm centers, as specified.

Process-wetted parts material:

Remark: Sensor gasket :
Viton o-ring or PTFE square section gasketAvailability of above material design depends on ranges and static pressure.Refer to "Code symbols".

Non-wetted parts material:

Electronics housing:
Low copper die-cast aluminum alloy finished with polyester coating (standard), or 316 stainless steel, as specified.
Bolts and nut:
Cr-Mo alloy (standard), or 316 SS
Option : 630/304 SS or 660/660 SS
Fill fluid: Silicone oil

Material code (7th digit in Code symbols*)	Process cover	Diaphragm	Wetted sensor body	Vent/drain
V	316 stainless steel (*1)	316L stainless steel	316 stainless steel	316/316L stainless steel
H	316 stainless steel (*1)	Hastelloy-C	Hastelloy-C lining	316/316L stainless steel
M	316 stainless steel (*1)	Monel	Monel lining	316/316L stainless steel
T	316 stainless steel (*1)	Tantalum	Tantalum lining	316/316L stainless steel

Note: (*1) SCS14A per JIS G 5121 (equivalent CF8M per ASTM A351/A351M)

Mounting bracket: 304 SS.

Environmental protection:

IEC IP67 and NEMA 6/6P

Mounting:

Without mounting bracket : direct mounting on mani-fold (optional)
With optional mounting bracket : for 50mm (2") pipe or direct wall mounting.

Mass{weight}:

Transmitter approximately 2.9 to 3.4kg without options.
Add: 0.5kg for mounting bracket
4.5kg for stainless steel housing option

Optional features

Indicator:

A plug-in analog indicator (2.5% accuracy)
An optional 5-digit LCD meter with engineering unit is also available.

Local configurator with LCD display:

An optional 5 digits LCD meter with 3 push buttons can support items as using communication with FXW.

Arrester:

A built-in arrester protects the electronics from lightning surges.
Lightning surge immunity: 4kV (1.2 × 50μs)

Degreasing:

Process-wetted parts are cleaned, but the fill fluid is standard silicone oil. Not for use on oxygen or chlorine measurement.

NACE specification:

Metallic materials for all pressure bound ary parts comply with NACE MR-01-75. 630/304 or 660/660 stain-less steel bolts and nuts comply with NACE.

Optional tagplate:

An extra stainless steel tag for customer tag data is wired to the transmitter.

ACCESSORIES

Oval flanges:

Converts process connection to 1/2-14 NPT in 316 stainless steel.

Hand held communicator:







(Model FXW, refer to Data Sheet No. EDS 8-47)

ORDERING INFOMATION



When ordering this instrument, specify.

1. CODE SYMBOLS
2. Measuring range.
3. Output orientation (burnout direction) when abnormality is occurred in the transmitter.
Hold / Overscale / Underscale
Unless otherwise specified, output hold function is supplied.
4. Indication method (indicated value and unit) in case of the actual scale (code D, H, P, S on 9th digit).
5. Tag No. (up to 20 alphanumeric characters), if required.


CODE SYMBOLS

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	DESCRIPTION
				5												Approvals for hazardous locations (consult FUJI for availability)
A																None (standard)
X																Flameproof housing ATEX  II 2 GD - Ex d IIC T5/T6 (code 4 = "M, P, R, T" & "W" only)
K															(*6)	Intrinsic Safety ATEX  II 1 GD - Ex ia IIC T4/T5
D															(*5)	FM - Flameproof housing Class I, Division 1, Groups B,C,D; T6 Dust ignitionproof Class II/III, Division 1, Groups E,F,G; T6; Type 4x - (code 4 = "P" & "T" only)
E																CSA - Flameproof housing Class I, Groups C,D - Class II, Group E,F,G Class III - (code 4 = "P" & "T" only)
H																FM - Intrinsic safety Class I, II, III, Division 1, Group A,B,C,D,E,F,G; T4 Non-Incendive Class I,II,III, Division 2, Groups A,B,C,D,F,G; T4; Type 4x
J																CSA - Intrinsic safety & Non-Incendive Class I, Groups A,B,C,D - Class II, Groups E,F,G - Class III
P																Type n ATEX  II 3 GD - Ex nA / Ex nL IIC T4/T5
Q																IECEX Type n
R																IECEX Flameproof housing Ex d IIC T5/T6 (code 4 = "M, P, R, T" & "W" only)
T																IECEX Intrinsic safety Ex ia T4/T5
L																Combined CSA approval for flameproof and Intrinsic safety (code 4 = "P" & "T" only)
M																Combined ATEX approval for flameproof and Intrinsic safety (code 4 = "M, P, R, T" & "W" only)
N																Combined IECEX approval for flameproof and Intrinsic safety (code 4 = "M, P, R, T" & "W" only)
V																Combined FM approval for flameproof and Intrinsic safety (code 4 = "P" & "T" only)
																Fieldbus Foundation™ & Profibus
A																None (standard)
X																Flameproof housing ATEX  II 2 GD - Ex d IIC T5/T6
K															(*6)	Intrinsic Safety ATEX  II 1 GD - Ex ia IIC T4
4																ATEX - FISCO  II 1 GD - Ex ia IIC T4
																Side vent/drain and mounting bracket
																Side vent/drain
																Mounting bracket
A																None
C																None
D																Yes, stainless steel
F																Yes
																Yes, stainless steel
																SS parts
																SS tag plate
																SS housing
Y																None
B																None
C																Yes
E																None
																Yes
																Special applications and fill fluid
																Treatment
																Fill fluid
Y																None (standard)
G																Degreasing
N															(*4)	NACE specification
																Silicone oil
																Silicone oil
																Silicone oil
																Process cover gasket
																Viton
- A																PTFE square section gasket in SS flange
- C																PTFE square section gasket in PVDF insert
- D															(*3)	PTFE square section gasket in PVDF insert
																Bolts/screws material
A																Carbon steel Cr-Mo (standard) M10
U																SS 316/316 (bolt/nuts) M10
F																SS 630/304 (bolt/nuts) M10
																Special options or design
(*2)																special, no code available

Notes :

- *1 Turn down of 100 : 1 is possible, but it should be used at a span greater than 1/40 of the maximum span for better performance.
- *2 When no code can be found in the current code symbols, place * in concerned code digit(s) & add * in 16 th digit
- *3 Process cover with PVDF insert with 1/2-18 NPT side process connection/no vent drain, other upon request - square section PTFE gasket
- *4 Our stainless steel bolts/nuts in SS630 and SS660 are in conformity with the NACE requirements and must be used for NACE service
- *5 Code "D & V" FM approval only possible with electrical connection 1/2" NPT.
- *6 For FKA transmitter, please use approval ATEX  II 1 GD - EEx ia IIC T4/T5 and for FDA transmitter ATEX  II 1 GD - EEx ia IIC T4

OUTLINE DIAGRAM (Unit:mm)




4th digit of the code symbols	Conduit conn.			Press. conn.	Oval frange screw
	D	E	F	G	
R	M20x1.5	16	5	1/4-14NPT	7/16-20UNF
T	1/2-14NPT	16	5	1/4-14NPT	7/16-20UNF
V	Pg13.5	8	4.5	1/4-14NPT	M10 or M12
W	M20x1.5	16	5	1/4-14NPT	M10 or M12
X	Pg13.5	8	4.5	1/4-14NPT	7/16-20UNF

TABLE 1

NOTE1) IN CASE OF 10TH CODE "C", $\phi 11$ CABLE IS SUITBLE.
NOTE2) WHEN THE 7TH DIGIT OF THE CODE SYMBOLS "H,M,T"

CONNECTION DIAGRAM



The product conforms to the requirements of the Electro-magnetic compatibility Directive 89/336/EEC as detailed within the technical construction file number TN513035. The applicable standards used to demonstrate compliance are :

EMI (Emission) EN61326 : 1997

Class A (std for Industrial Location)

Frequency range MHz	Limits	Reference Standard
3 to 230	40dB (µV/m) quasi peak measured at 10m distance	CISPR16-1 and CISPR16-2
230 to 1000	47dB (µV/m) quasi peak, measured at 10m distance	

Note) Definition of performance criteria

- A : During testing, normal performance within the specification limits**
- B : During testing, temporary degradation, or loss of function or performance which is self-recovering.**

EMS (Immunity) EN61326 : 1997

Annex A (standard for Industrial Location)

Phenomenon	Test value	Basic Standard	Performance criteria
Electrostatic discharge	4kV (Contact) 8kV (Air)	IEC61000-4-2	B
Electromagnetic field	80 to 1000MHz 10V/m 80%AM (1kHz)	IEC61000-4-3	A
Rated power frequency magnetic field	30A/m 50Hz	IEC61000-4-8	A
Burst	2kV 5kHz	IEC61000-4-4	B
Surge	1.2µs/50µs 1kV (Line to line) 2kV (line to ground)	IEC61000-4-5	B
Conducted RF	0.15 to 80MHz 3V , 80%AM (1kHz)	IEC61000-4-6	A

Fuji Electric France S.A.

46, Rue Georges Besse - Z I du Brézet

63 039 Clermont-Ferrand cedex 2 — FRANCE

France : Tél. 04 73 98 26 98 - Fax 04 73 98 26 99

International : Tél. (33) 4 7398 2698 - Fax. (33) 4 7398 2699

E-mail : sales.dpt@fujielectric.fr

Web : www.fujielectric.fr

Fuji Electric can accept no responsibility for possible errors in catalogues, brochures and other printed material. Fuji Electric reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without subsequential changes being necessary in specifications already agreed. All trademarks in this material are property of the respective companies. All rights reserved.